


REFRIGERATION: COIL: RUSSELL CTA 46-140.  
 20,958 BTU/hr @ 20°F  
 ø1/2IN ODS LIQUID.  
 ø7/8IN ODS SUCTION.

TOP AREA: 145.0 SQR FEET.

ELECT. LOADS: 115V, 24.0A, 60HZ, 1PH.  
 ALL ELECT LOADS MAXIMUM AND INCLUDE THE FOLLOWING:  
 (1) CTA COILS 4.4A, (6) WOD BALLAST 14.4A,  
 (4) TROFFERS BALLASTS 3.76A.

NOTES:

1. OPTIONS NOT SHOWN ON DRAWING SHOULD BE LISTED IN WRITTEN PROPOSAL AND LISTED ON PURCHASE ORDER.
2. ELEC. CONNECTION: 115V/230V, 4x4 SUPPLY BOX AS NEEDED.
3. EXPANSION VALVES: SPORLAN "Q" SERIES STANDARD UNLESS OTHERWISE SPECIFIED.
4. DEFROST CONTROL: REMOTE CASES (N/A, DIGITAL CASE CONTROLLERS AVAILABLE), OPTIONAL CONDENSING UNIT (DIGITAL CASE CONTROLLER).
5. THERMOSTATS & LIQUID LINE SOLENOID VALVES: OPTIONAL.
6. DRAIN: 1 1/2 INCH PVC.
7. SPECIFICATIONS SUBJECT TO CHANGE WITHOUT NOTICE.

AUTHORIZATION (PRINT):	DATE:	 <b>börger systems</b>		DRAWN BY: D HUNT
SIGNATURE:				SCALE: 1:x
		DATE: 7-21-99	(2) 3DR WOD & 1 BTD	
DATE	REV.	DIM: INCH	DRAWING NUMBER	
REVISION	TOL:		P3091A	